

The Polyethersulfone membrane filter has been manufactured in a **mdi** facility in compliance with **ISO 9001** regulations using *validated production processes*.

Certificate of Quality

AseptiCap KS-Y PES Membrane Filters

Catalog No.	: IKSX1001BBRX101
Туре	: IKS
Pore Size	: 0.2 μm (0.45 μm + 0.2 μm)
Lot Number	: IK9224L
Manufacturing Date	: 2024 - 12
Expiry Date	: 2029 - 12

SPECIFICATION

Membrane Housing Filter Diameter Effective Filtration Area (Nominal) Burst pressure Sterilization	: Polyethersulfone : Polypropylene : 50 mm : 20 cm ² : > 8 Kg/cm ² : Can be sterilized by Gamma Irradiation upto 50 kGy
LOT RELEASE CRITERIA	
100% Integrity Tested	: The filter has been tested for integrity by Bubble Point Test using purified water. Bubble point was: ≥ 50 psi (3.44 Bar)
Typical Water Flow Rate	: 175 ml/min @ 0.70 kg/cm ² @ 27 °C
Microbial Challenge Test	: Retains $\ge 10^7$ organisms/cm ² of <i>B. diminuta</i> ATCC 19146 challenge as per ASTM F838 methodology.
VALIDATED FOR	
Bubble point (50% IPA)	: The filter is certified/validated for integrity by Bubble point test using 50% IPA/Water solution. Bubble point ≥ 18 psi (1.24 Bar)
Bacterial Endotoxin	: Aqueous extracts exhibit < 0.25 EU/mL as established by Limulus Amebocyte Lysate (LAL) test as per USP <85>.
Biosafety	Passes Biological Reactivity Tests, <i>In Vivo</i> for Class VI plastic as described in USP <88>.
Cytotoxicity	: Passes Biological Reactivity Tests, In Vitro as described in USP <87>.
Indirect Food Additives	Passes as per FDA 21CFR 177.1520(a)1(i).
Particle Release	: Passes test as per USP <788>, "Particulate matter in Injections".
Fiber Release	Complies with FDA 21CFR 210.3(b)(6).
Extractable	: Within limits as specified in USP.
Oxidizable matter	: Passes test as per USP.
Total Organic Carbon	: Meets USP <643> limit of 500 ppb for total organic carbon after flushing specified volume of water for injection.
Conductivity	: Meets USP <645> limit of 1.3 μS/cm at 25 °C for water conductivity after flushing specified volume of water for injection.
PRECAUTIONS	

1. During handling, avoid contamination of outlet.

2. If pressure required to maintain the required flow becomes too high, the filter unit should be changed.

CUSTOMER SUPPORT

mdi offers its unique interdisciplinary skills to provide solutions to specific problems. Please contact our factory or the local application specialist.

T. No.: COQ/ILF/007-03

han

Head of Quality Assurance Issue Date: 14-Dec-24 Advanced Microdevices Pvt. Ltd.

Jawahargarh Road, Village-Tepla, Ambala, INDIA. Tel: +91-171-2699290/2699274 Website: www.mdimembrane.com Email: info@mdimembrane.com

An ISO 9001 Company