

Certificate of Quality

The Polyethersulfone membrane filter has been manufactured in a **mdi** facility in compliance with **ISO 9001** regulations using *validated production processes*.

AseptiCap KL-γ PES Membrane Filters

Catalog No. : VKLX1002SSRX102

Type : VKL
Pore Size : 0.45 µm
Lot Number : IK9564K
Manufacturing Date : 2024 - 11
Expiry Date : 2029 - 11

SPECIFICATION

Membrane : Polyethersulfone Housing : Polypropylene

Filter Diameter : 50 mm

Effective Filtration Area (Nominal) : 20 cm²

Burst pressure :> 8 Kg/cm²

Sterilization : Can be sterilized by Gamma Irradiation upto 50 kGy

LOT RELEASE CRITERIA

The above lot meets the following lot release criteria:

100% Integrity Tested: The filter has been tested for integrity by Bubble Point Test using purified water.

Bubble point was: ≥ 30 psi (2.07 Bar)

Typical Water Flow Rate : 450 ml/min @ 0.70 kg/cm² @ 27 °C

VALIDATED FOR

Bubble point (50% IPA) : The filter is certified/validated for integrity by Bubble point test using 50%

IPA/Water solution. Bubble point ≥ 10 psi (0.69 Bar)

Microbial Retention: Retains microbial challenge of *S. marcescens* (ATCC 14756).

Bacterial Endotoxin : Aqueous extracts exhibit < 0.25 EU/mL as established by Limulus Amebocyte

Lysate (LAL) test as per USP <85>.

Particle Release : Passes test as per USP <788>, "Particulate matter in Injections".

Fiber Release : Complies with FDA 21CFR 210.3(b)(6). Extractable : Within limits as specified in USP.

Oxidizable matter : Passes test as per USP.

Biosafety : Passes Biological Reactivity Tests, In Vivo for Class VI plastic as described in USP

<88>.

Cytotoxicity : Passes Biological Reactivity Tests, *In Vitro* as described in USP <87>.

Indirect Food Additives : Passes as per FDA 21CFR 177.1520(a)1(i).

Total Organic Carbon : Meets USP <643> limit of 500 ppb for total organic carbon after flushing specified

volume of water for injection.

Conductivity : Meets USP <645> limit of 1.3 μ S/cm at 25 °C for water conductivity after flushing

specified volume of water for injection.

PRECAUTIONS

1. During handling, avoid contamination of outlet.

2. If pressure required to maintain the required flow becomes too high, the filter unit should be changed.

CUSTOMER SUPPORT

mdi offers its unique interdisciplinary skills to provide solutions to specific problems. Please contact our factory or the local application specialist.

T. No.: COQ/ILF/007-03

Om

Head of Quality Assurance

Issue Date: 07-Nov-2024

Advanced Microdevices Pvt. Ltd.

21, Industrial Area, Ambala Cantt, INDIA, Tel: +91-171-2699290/ 2699274
Website: www.mdimembrane.com
Email: info@mdimembrane.com

An ISO 9001 Company